



**ROXBOROUGH
WATER AND SANITATION DISTRICT
2022**

Supplying a safe and dependable water supply is our number one goal. We are pleased to present the 2021 Water Quality Report to assure you the District's water has again met and exceeded the State's water quality standards.

**Source Water Assessment and
Protection (SWAP)**

The Colorado Department of Public Health & Environment (CDPHE) has completed a source water assessment of the potential for contaminants reaching any of Aurora Water's terminal supplies, the last stop for the water before it is treated by the District for your use. The potential sources of contamination that may exist are:

- EPA areas of concern
- permitted wastewater discharge sites
- above ground, underground and leaking storage tank sites
- solid waste sites
- existing or abandoned mine sites
- other facilities
- commercial, industrial and transportation activities
- residential, urban recreational grasses
- quarries, strip mines and gravel pits
- agriculture
- forests
- septic systems
- oil and gas wells and roads

For more information on the report, contact the CDPHE by calling 303.692.2000 or visiting Colorado.gov/cdphe/CCR. The report is located under "Guidance: Source Water Assessment Reports."

If you have any questions about this report or concerning your water or wastewater services, please call the District office at 303.979.7286.

The District's Board of Directors meetings are held on the third Wednesday of every month at 8:00 am. Please feel free to attend these meetings. Meeting format is currently hybrid with both in-person and virtual options to attend and participate.

Esta es información importante. Si no la pueden leer, necesitan que alguien se la traduzca

DRINKING WATER CONSUMER CONFIDENCE REPORT FOR CALENDAR YEAR 2021

PWSID: CO 0118055

ROXBOROUGH WATER AND SANITATION DISTRICT
6222 N Roxborough Park RD • Littleton CO 80125 303.979.7286
www.roxwater.org

Our Water Source

The District receives our source water from the City of Aurora. The water is diverted from the South Platte River at Strontia Springs Reservoir and then runs through the City of Aurora's tunnel to the Rampart Reservoir and transmission pipelines to the District's water treatment facility. Once it reaches the treatment facility, we utilize several treatment processes including coagulation, flocculation, sedimentation, filtration and disinfection.

The sources of drinking water (both tap water and bottled water) include lakes, rivers, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial Contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic Contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and Herbicides, which may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.
- Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive Contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the public in general. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. Immunocompromised persons, such as persons with cancer, undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice from their health care providers about drinking water. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants call the EPA Safe Drinking Water Hotline at 1-800-426-4791.

In order to ensure that tap water is safe to drink, Colorado Department of Public Health and Environment prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The US Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water that must provide the same protection for public health.



- **Maximum Contaminant Level (MCL)** – The highest level of a contaminant allowed in drinking water.
- **Treatment Technique (TT)** – A required process intended to reduce the level of a contaminant in drinking water.
- **Action Level (AL)** – The concentration of a contaminant which, if exceeded, triggers treatment and other regulatory requirements.
- **Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Contaminant Level Goal (MCLG)** – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Violation (No Abbreviation)** – Failure to meet a Colorado Primary Drinking Water Regulation.
- **Formal Enforcement Action (No Abbreviation)** – Escalated action taken by the State (due to the risk to public health, or number or severity of violations) to bring a non-compliant water system back into compliance.
- **Variance and Exemptions (V/E)** – Department permission not to meet a MCL or treatment technique under certain conditions.
- **Gross Alpha (No Abbreviation)** – Gross alpha particle activity compliance value. It includes radium-226, but excludes radon 222, and uranium.
- **Picocuries per liter (pCi/L)** – Measure of the radioactivity in water.
- **Nephelometric Turbidity Unit (NTU)** – Measure of the clarity or cloudiness of water. Turbidity in excess of 5 NTU is just noticeable to the typical person.
- **Compliance Value (No Abbreviation)** – Single or calculated value used to determine if regulatory contaminant level (e.g. MCL) is met. Examples of calculated values are the 90th Percentile, Running Annual Average (RAA) and Locational Running Annual Average (LRAA).
- **Average (x-bar)** – Typical value.
- **Range (R)** – Lowest value to the highest value.
- **Sample Size (n)** – Number or count of values (i.e. number of water samples collected).
- **Parts per million = Milligrams per liter (ppm = mg/L)** – One part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion = Micrograms per liter (ppb = ug/L)** – One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **Parts per trillion = Nanograms per liter (ppt = ng/L)** – One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.
- **Parts per quadrillion = Picograms per liter (ppq = pg/L)** – One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.
- **Not Applicable (N/A)** – Does not apply or not available.

Additional Information

Nitrate in drinking water at levels above 10 ppm (10,000 ppb) is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue-baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.

If arsenic is less than 10 ppb, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health affects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Roxborough Water and Sanitation District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

Roxborough...A Water Efficient Community

With the natural beauty of the area, we all agree this is a great place to live or work. Indeed, the Roxborough area is one of the most majestic communities in Colorado. That is why it is up to all of us who live and work in the community to conserve our limited water resources now and into the years ahead. To do that, we must all take the right steps to discover the beauty of being a water efficient community. Together, "WE" can become one of the Colorado's most Water-Efficient communities!

Roxborough Water & Sanitation District Violations for Reporting Year:

- No Violations or Formal Enforcement Actions.

Contaminants that were tested for, but not detected, include:

- Fecal coliforms, E.Coli, and all regulated & unregulated volatile & synthetic organic chemicals including pesticides & herbicides.

The state grants waivers for some drinking water contaminants if the contaminants are not found in the public water system's source water. The District has been granted waivers for the following contaminants:

- Dioxin, glyphosate, cyanide, asbestos

The Table of Detected Contaminants

The following definitions will help you understand the terms and abbreviations used in this report:

- **Maximum Contaminant Level (MCL)** – The highest level of a contaminant allowed in drinking water.
- **Treatment Technique (TT)** – A required process intended to reduce the level of a contaminant in drinking water.
- **Action Level (AL)** – The concentration of a contaminant which, if exceeded, triggers treatment and other regulatory requirements.
- **Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Contaminant Level Goal (MCLG)** – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Violation (No Abbreviation)** – Failure to meet a Colorado Primary Drinking Water Regulation.
- **Formal Enforcement Action (No Abbreviation)** – Escalated action taken by the State (due to the risk to public health, or number or severity of violations) to bring a non-compliant water system back into compliance.

Water Quality Data

We routinely monitor for contaminants in your drinking water according to Federal and State laws. The State of Colorado requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Some of our data, though representative, may be more than one year old.

These tables show the results of our monitoring for the period of **January 1 to December 31, 2021** unless otherwise noted.

Treatment

Turbidity									
Turbidity ¹	TT Requirement		Level Found			Violation (Yes or No)	Sample Date	Likely Source of Contamination	
	Maximum 1,000 NTU for any single measurement		Highest single measurement: 0.22				Date: 06/28/2021		
	In any month, at least 95% of samples must be less than 0.3 NTU		Lowest monthly percentage of samples meeting TT standard for our technology: 100%			No	Month: N/A		
Total Organic Carbon									
Contaminant	Compliance Factor (measurements should not be lower than this factor**)		Range of Individual Ratio Samples (Lowest-Highest)		Running Annual Average Range for the Year (compliance factor)		Violation (Yes or No)	Sample Date/Year	Likely Source of Contamination
Total Organic Carbon Ratio (TOC)	1.0		0.68 - 1.54		1.04		No	*RAA	Naturally present in the environment

Footnotes:¹ Turbidity is a measure of the cloudiness of the water. We monitor turbidity because it is a good indicator of the effectiveness of our filtration system.

**If minimum ratio not met and no violation identified then the system achieved compliance using alternative criteria.

*RAA- Running Annual Average

Entry Point to Distribution System

Inorganic Contaminants								
Contaminant	MCL	MCLG	Sample Size	Units	Level Detected/Range	Violation (Yes or No)	Sample Date	Likely Source of Contamination
Antimony	6	6	1	ppb	<1	No	01/26/2021	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic	10	0	1	ppb	<1	No	01/26/2021	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	2,000	2,000	1	ppb	41	No	01/26/2021	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium	4	4	1	ppb	<1	No	01/26/2021	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium	5	5	1	ppb	<1	No	01/26/2021	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
Chromium	100	100	1	ppb	1	No	01/26/2021	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride	4,000	4,000	1	ppb	470	No	01/26/2021	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (inorganic)	2	2	1	ppb	<0.1	No	01/26/2021	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Nickel	100	100	1	ppb	2	No	01/26/2021	Natural Deposits and Industrial Processes
Nitrate (as Nitrogen)	10,000	10,000	1	ppb	200	No	01/26/2021	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (as Nitrogen)	1,000	1,000	1	ppb	<100	No	01/13/2020	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	50	50	1	ppb	1	No	01/26/2021	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Thallium	2	0.5	1	ppb	<1	No	01/26/2021	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

Radionuclides

Contaminant Name	Year	Average of Individual Samples	Range of Individual Samples (Lowest - Highest)	Sample Size	Unit of Measure	MCL	MCLG	MCL Violation?	Typical Sources
Combined Radium (-226 & -228)	2020	0.6	0.2 – 1.0	1	pCi/L	5	0	No	Erosion of natural deposits.
Gross Alpha, Excl. Radon & U	2020	0.9	0.9 - 0.9	1	pCi/L	15	0	No	Erosion of natural deposits.
Radon	2011	7	7 - 7	1	pCi/L			No	Naturally present in the environment.

Secondary Contaminants

Contaminant	Secondary Standard	MCLG	Units	Level Detected/Range	Violation (Yes or No)	Sample Size	Sample Date	Likely Source
Sodium	10,000	N/A	ppm	22.4	N/A	1	01/26/2021	Erosion of Natural Deposits

Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects or aesthetic effects in drinking water. EPA recommends these standards but does not require water systems to comply.

Water Quality Data cont.



Distribution System

Microbiological Contaminants

Contaminant	MCL	MCLG	Units	Result	Violation (Yes or No)	Sample Size	Sample Date	Likely Source of Contamination
Total Coliform Bacteria for Systems that collects <40 samples per month	No more than 1 positive monthly sample	0	Absent or Present	Absent	No	10	n/a	Naturally present in the environment

Disinfectant Residuals

Disinfectant Name	MRDL	MRDLG	Units	Range & Average	Violation (Yes or No)	Sample Size	Sample Date	Source
Chlorine/ Chloramine	4	4	ppm	0.76-3.00 2.26	No	10	01/20/2021	Water additive used to control microbes

Disinfection Byproducts

Contaminant	MRDL	MCLG	Units	Average	Range	Violation (Yes or No)	Sample Size	Sample Date	Source
Haloacetic Acids (HAA5)	60	N/A	ppb	10.02	5.3 – 20.0	No	16	*RAA	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM)	80	N/A	ppb	21.93	9.8 – 61.7	No	16	*RAA	Byproduct of drinking water disinfection

Lead and Copper

Contaminant	AL	ALG	Units	90 th Percentile	Number of Sites over AL	Violation (Yes or No)	Sample Size	Sample Date	Likely Source of Contamination
Copper	1,300	1,300	ppb	26	0	No	30	06/23/2021-06/30/2021	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead	15	0	ppb	3	0	No	30	06/23/2021-06/30/2021	Corrosion of household plumbing systems, erosion of natural deposits

UCMR4 - Unregulated Contaminants Monitoring Rule

Source	Contaminant Name	Year	Average	Range	Sample Size	Unit of Measure	MCL	Likely Source
Raw Water	Bromide	2020	30.5	30.5	1	ppb	NA	Erosion of natural deposits
	Total Organic Carbon (TOC)	2020	2590	2590	1	ppb	NA	Erosion of natural deposits
Entry Point	Manganese	2020	27.2	27.2	1	ppb	NA	Erosion of natural deposits
Distribution System	Bromoacetic Acid	2020	2.29	2.25 - 2.33	4	ppb	NA	Byproducts of drinking water disinfection
	Bromodichloroacetic Acid	2020	1.24	1.15 - 1.35	4	ppb	NA	Byproducts of drinking water disinfection
	Chlorodibromoacetic Acid	2020	0.493	0.465 - 0.517	4	ppb	NA	Byproducts of drinking water disinfection
	Dibromoacetic Acid	2020	0.534	0.528 - 0.540	4	ppb	NA	Byproducts of drinking water disinfection
	Dichloroacetic Acid	2020	4.91	4.36 - 5.33	4	ppb	NA	Byproducts of drinking water disinfection
	Trichloroacetic Acid	2020	2.13	2.07 - 2.28	4	ppb	NA	Byproducts of drinking water disinfection

EPA has implemented the Unregulated Contaminant Monitoring Rule (UCMR) to collect data for contaminants that are suspected to be present in drinking water and do not have health-based standards set under the Safe Drinking Water Act. EPA uses the results of UCMR monitoring to learn about the occurrence of unregulated contaminants in drinking water and to decide whether or not these contaminants will be regulated in the future. We performed monitoring and reported the analytical results of the monitoring to EPA in accordance with its Unregulated Contaminants Monitoring Rule (UCMR). Once EPA reviews the submitted results, the results are made available in the EPA's National Contaminant Occurrence Database (NCOD) (<https://www.epa.gov/sdwa/national-contaminant-occurrence-database-ncod>). Consumers can review UCMR results by accessing the NCOD. Contaminants that were detected during our UCMR sampling and the corresponding analytical results are provided above if any.

Violations, Significant Deficiencies, and Formal Enforcement

Health-Based Violations

Maximum contaminant level (MCL) violations: None

Treatment technique (TT) violations: None

Name	Description	Time Period	Health Effects	Compliance Value	TT Level or MCL
NONE	No Violations or Formal Enforcement Actions				

Additional Violation Information