

## Water Plant

The water treatment plant has been running smoothly. In October, the plant was operational for **26** days with an average plant production of **1.68** MGD and a max day of **2.57** MGD.

Our sludge project is nearly complete we are down to only a few feet left to manage. Once completed we will make the necessary repairs to the sludge collect and place the west basin back into service.

The operators have moved to the winter schedule; recall this schedule leaves the plant off on the weekend and utilizes excess storage to satisfy demands on Saturdays and Sundays.

October production was **43.9** million gallons of treated water, **12** million gallons of that was for Sterling Ranch.

## Lift Stations

The lift stations are running smoothly. We are currently experiencing odor issues at the Roxborough Lift Station, we believe these are directly related to Sterling Ranch however we are evaluating odor bed media replacement. By attempting to cover the splitter structure and grinder vault the odors migrated into the collection system resulting in nuisance calls from Ravenna.

October saw **20** million gallons of sewage pumped to Littleton-Englewood. Approximately **2.3** million was conveyed for Sterling Ranch.

## Field

The field remains busy for October with over **502** locates with the majority in Sterling Ranch. A total of **141** were for Roxborough.

Design for the upsize of the north loop 12" transmission line in Rampart Range Road continues. We are working through the final alignment however have run into some conflict with Roxborough Village Metro on the west side of Rampart Range Rd. Apparently, there is a spot reserved for a pool near our proposed alignment.

We have scheduled two public Zoom meeting with the folks on Rock Wren and Hawks Nest Trl. for the water and sewer line replacement project.